



**NOTES:**

1. BEDDING & BACKFILL MATERIAL MUST BE APPROVED BY LEHI POWER
2. INSPECTION REQUIRED PRIOR TO BACKFILL COMPACTION TESTING REQUIRED. REFER TO 4.2.1
3. SERVICE LATERAL DEPTH 36" MINIMUM.
4. PROVIDE BEDDING ON ALL CONDUIT SURFACES AND 6" SEPARATION BETWEEN POWER CONDUITS
5. PROVIDE DEPTH OF 1 FOOT TO TOP OF CONDUIT FOR EVERY 1 INCH OF NOMINAL DIAMETER
6. LEHI POWER REQUIRES A SINGLE 2" DIAMETER CONDUIT TO ACCOMPANY ALL POWER CONDUIT RUNS.



**REQUIREMENTS & STANDARDS**

**POWER TRENCH &  
JOINT USE TRENCH DETAIL**

**RESIDENTIAL & COMMERCIAL SUBDIVISION**

DWG: **4.2.2**

REV. 0.00

BY: GWK/BT

DATE: 01/5/17